



A Joint Venture of Andhra Pradesh Gas Distribution Corporation Ltd. and
Hindustan Petroleum Corporation Ltd

REPLIES TO THE BIDDER'S QUERIES

Date: 29.12.2020

Tender Document No: GGPL/C&P/HT/5000011/2020-21/03 Dt. 14.12.2020

Subject: Tender for Hiring of Agency for Hydrotesting of cascades on ARC Basis

Replies to the Bidder's Queries

SR. NO.	TENDER CLAUSE	PAGE NO.	BIDDER'S QUERY	GGPL'S REPLY
1	Clause 10, Spare List, SECTION – VII Special Conditions of Contract	Page 174	There is no specification (Like Make,Size,Type etc...) given in the list along with a spare name, we would like to know about Bill of Material to quote that particular item..	The Pressure Gauge Specification is as follows: Make: General/Wika/Baumer End Connection : 1/2" NPT Range: 400 BAR/5800 PSI Dial Size: 4" DIAL Glycerine filled Pressure Gauge

All other terms and conditions of tender document remain unchanged

Authorized Signatory